CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEEDING. PUBLISHING MATERIALS LISTING PROCEDUM.

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 4175-0767:101 Page 1 of 1

CATEGORY: Roof Covering (Miscellaneous)

LISTEE: United Coatings, 19011 E. Cataldo, Greenacres, WA 99016

Contact: Jeff Carce (509) 926-7143

DESIGN: Type "Diathon Elastomer Acrylic Coating" roof coating material. Refer to listee's data sheet

and UL Roofing Materials and Systems Directories for detailed product description and

operational considerations. Approved systems:

CLASS A:

Deck:NC Incline:2

Foam: IPI, Div. of PMC "1570", any thickness

Base: Diathon Elastomer Acrylic Coating, 1-1/4 to 2 Gal/sq⁽¹⁾ total (20-32 wet mils) Surfacing: Diathon Elastomer Acrylic Coating, 1-1/4 to 2 Gal/sq tolal (20-32 wet mils)

Deck:NC Incline:2

Foam: Foam Enterprises "FE-303", any thickness

Base Coat: Diathon Elastomer Acrylic Coating, 1-1/4 to 2 Gal/sq total (20-32 wet mils) Surfacing: Diathon Elastomer Acrylic Coating, 1-1/4 to 2 Gal/sq total (20-32 wet mils)

 $^{(1)}$: Gal/sq = gallon per 100 ft²

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product name and UL label.

APPROVAL: Listed as Class A roof covering assemblies as described under "Design" and when

constructed in accordance to UL Directory.

11-12-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 15, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager